

---

## *Addendum 02*

---

TO: All Parties  
FROM: Gaston County Schools  
TODAY'S DATE: June 19, 2025  
REGARDING IFB: Emergency Responder Communication Coverage System  
ADDENDUM NO: 02

Your attention is called to the following question(s) from one or more vendors:

**Question 1:**

At the kick off meeting I believe you mentioned that grid tests and IB Wave be completed for each school before bids could be submitted. Can you confirm that is accurate?

**Response 1:**

No, that was not stated at the kick off meeting and is not accurate. However, for clarity, the following item is noted:

- 1) See page 5 of the IFB which states that "the installer shall provide a 20-grid hard copy floor plan for each floor with the signal reading noted for the center of each grid for all relevant radio systems" after installation of the ERRCS at each location as part of the acceptance test which shall be conducted by the vendor and may be verified by City and County Fire Marshals and School Officials.

**Question 2:**

Also, can you please list the preferred contractors that perform work at your schools? Electrical, roofing, fire alarm, etc.

**Response 2:**

GCS Facilities Services team members indicates the following:

Electrical: Dallas Electrical & Plumbing Contractors, Inc., 114 E. 2<sup>nd</sup> Ave, Gastonia, NC 28052

Roofing: Carver & Sons Roofing, Inc., 914 Dr M.L.K. Jr. Way, Gastonia, NC 28054

Fire Alarm: Johnson Controls (Simplex 4020, Simplex 4100U), Coastal Security (Fire-Lite MS-9600, EST io500, EST 3, Fire-Lite ES-200 *at Cramerton Middle School*, Fire-Lite MS-9200, Fire-Lite ES-1000), ADM (Silent Knight 6820 EVS, Silent Knight 5808), LEI Systems (Notifier 3030, Notifier NFS 320, Notifier AFP 400, Notifier NFS 640, Notifier Firewarden 100), City Fire & Safety (Fire-Lite ES-1000, Gamewell S3, Fire-Lite ES-200 *at New Hope Elementary School*)

END OF ADDENDUM 02